

CERTIFICATE OF COMPLIANCE

Certificate Number 20180518-E489210
Report Reference E489210-20180517
Issue Date 2018-MAY-18

Issued to: SERMATEX GRUN EQUIP ELETRICOS LTDA
Rua Coronel Tristao 203
Sao Paulo-SP
02925-030 BRAZIL

**This is to certify that
representative samples of**

**AUXILIARY DEVICES FOR USE IN HAZARDOUS
LOCATIONS**

Industrial Control Devices, SG-Ex Series for Use in Class I, Division 1, Groups B, C, and D; Class II, Division 1, Groups E, F and G; Class III; Hazardous (Classified) Locations.

Model type SG-EX, followed by 22 or 26, followed by G, Z, Q, T, K or W, followed by BEG, BEMO, BES, BETR, BEY, BEY3, BEY5, BI, BIG, BK, BL, BR, BRG, BY, CA, CAG, CC, CCG, PL, followed by N, L or X, followed by additional characters or numbers that indicates colors and the additional electrical devices that are mounted with the equipment

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: REFER ADDENDUM PAGE FOR STANDARDS
Additional Information: See the UL Online Certifications Directory at www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number 20180518-E489210
Report Reference E489210-20180517
Issue Date 2018-MAY-18

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

UL 1203 - Explosion-Proof and Dust-Ignition-Proof Electrical Equipment for Use in Hazardous (Classified) Locations.


CAN/CSA C22.2 No. 30-M1986 - Explosion-Proof Enclosures for Use in Class I Hazardous Locations. Reaffirmed 2016

CAN/CSA C22.2 No. 25-1966 - Enclosures for Use in Class II Groups E, F, and G Hazardous Locations. Reaffirmed 2014.

UL 50 - Enclosures for electrical equipment

UL 508 & CSA C22.2 no. 14-13 - Standard for industrial control equipment

CSA C22.2 no. 94-M91 - Special purpose enclosures industrial product



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

